



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project 3rd Quarter 2017
Description End of Grant Rd

Lab Sample No. 1709244-001
Client Sample ID 710DQ
Matrix Drinking Water (Rep)
Date Received 09/12/17 14:10
Date Sampled 09/07/2017 12:30
Date Reported 9/26/2017

Test	Method	Result	Reporting Limit	Units	Analyst	Prep Date	Test Date	Qlf.
GC TTHM 524.3								
Total Trihalomethanes	EPA 524.3	0.004	0.001	mg/L	PW	Not Required	9/12/2017	
Chloroform	EPA 524.3	0.003	0.001	mg/L	PW	Not Required	9/12/2017	
Bromodichloromethane	EPA 524.3	0.001	0.001	mg/L	PW	Not Required	9/12/2017	
Dibromochloromethane	EPA 524.3	<0.001	0.001	mg/L	PW	Not Required	9/12/2017	
Bromoform	EPA 524.3	<0.001	0.001	mg/L	PW	Not Required	9/12/2017	

Approved By Carlton R. McCracken, Jr.
Carlton R. McCracken, Jr. Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project 3rd Quarter 2017
Description Boot Jack Tank

Lab Sample No. 1709247-001
Client Sample ID 712DQ
Matrix Drinking Water (Rep)
Date Received 09/12/17 14:10
Date Sampled 09/07/2017 11:30
Date Reported 9/19/2017

Test	Method	Result	Reporting Limit	Units	Analyst	Prep Date	Test Date	Qlf.
GC TTHM 524.3								
Total Trihalomethanes	EPA 524.3	0.049	0.001	mg/L	PW	Not Required	9/12/2017	
Chloroform	EPA 524.3	0.037	0.001	mg/L	PW	Not Required	9/12/2017	
Bromodichloromethane	EPA 524.3	0.010	0.001	mg/L	PW	Not Required	9/12/2017	
Dibromochloromethane	EPA 524.3	0.002	0.001	mg/L	PW	Not Required	9/12/2017	
Bromoform	EPA 524.3	<0.001	0.001	mg/L	PW	Not Required	9/12/2017	

Approved By

Carlton R. McCracken, Jr., Chemist



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com


Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project 3rd Quarter 2017
Description Boot Jack Pump

Lab Sample No. 1709246-001
Client Sample ID 714DQ
Matrix Drinking Water
Date Received 09/12/17 14:10
Date Sampled 09/07/2017 08:30
Date Reported 9/29/2017

Test	Method	Result	Reporting Limit	Units	Analyst	Prep Date	Test Date	Qlf.
GC HAAS								
Haloacetic Acids (HAA5)	EPA 552.3	7.37	2.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	
Monochloroacetic Acid (MCAA)	EPA 552.3	<2.00	2.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	
Monobromoacetic Acid (MBAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	
Dichloroacetic Acid (DCAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	
Trichloroacetic Acid (TCAA)	EPA 552.3	7.37	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	
Dibromoacetic Acid (DBAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 22:46:00	

Approved By 
Diane Kisner, Laboratory Manager

SWT - PA DEP Lab ID# 06-00208



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com


Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project 3rd Quarter 2017
Description Fairview Pump Station

Lab Sample No. 1709248-001
Client Sample ID 711DQ
Matrix Drinking Water
Date Received 09/12/17 14:10
Date Sampled 09/07/2017 12:00
Date Reported 9/29/2017

Test	Method	Result	Reporting Limit	Units	Analyst	Prep Date	Test Date	Qlf.
GC HAAS								
Haloacetic Acids (HAA5)	EPA 552.3	14.1	2.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	
Monochloroacetic Acid (MCAA)	EPA 552.3	<2.00	2.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	
Monobromoacetic Acid (MBAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	
Dichloroacetic Acid (DCAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	
Trichloroacetic Acid (TCAA)	EPA 552.3	14.1	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	
Dibromoacetic Acid (DBAA)	EPA 552.3	<1.00	1.00	µg/L	Sub-SWT	9/15/2017	9/25/2017 23:18:00	

Approved By 
Diane Kisner, Laboratory Manager

SWT - PA DEP Lab ID# 06-00208