



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com


Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project Quarterly
Description

Lab Sample No. 1712037-001
Client Sample ID 710DQ
Matrix Drinking Water (Rep)
Date Received 12/05/17 14:45
Date Sampled 12/05/2017 08:45
Date Reported 12/22/2017

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
GC TTHM 524.3									
Total Trihalomethanes	EPA 524.3	0.015	0.001		mg/L	PW	Not Required	12/12/17	
Chloroform	EPA 524.3	0.013	0.001		mg/L	PW	Not Required	12/12/17	
Bromodichloromethane	EPA 524.3	0.002	0.001		mg/L	PW	Not Required	12/12/17	
Dibromochloromethane	EPA 524.3	<0.001	0.001		mg/L	PW	Not Required	12/12/17	
Bromoform	EPA 524.3	<0.001	0.001		mg/L	PW	Not Required	12/12/17	

Approved By 
Diane Kisner, Laboratory Manager



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com


Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project Quarterly
Description

Lab Sample No. 1712037-002
Client Sample ID 711DQ
Matrix Drinking Water (Rep)
Date Received 12/05/17 14:45
Date Sampled 12/05/2017 08:30
Date Reported 12/22/2017

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
GC HAA5									
Haloacetic Acids (HAA5)	EPA 552.3	0.022	0.002		mg/L	PW	12/18/17	12/19/17	
Monochloroacetic Acid (MCAA)	EPA 552.3	<0.002	0.002		mg/L	PW	12/18/17	12/19/17	
Monobromoacetic Acid (MBAA)	EPA 552.3	<0.001	0.001		mg/L	PW	12/18/17	12/19/17	
Dichloroacetic Acid (DCAA)	EPA 552.3	0.013	0.001		mg/L	PW	12/18/17	12/19/17	
Trichloroacetic Acid (TCAA)	EPA 552.3	0.009	0.001		mg/L	PW	12/18/17	12/19/17	
Dibromoacetic Acid (DBAA)	EPA 552.3	<0.001	0.001		mg/L	PW	12/18/17	12/19/17	

Approved By 
Diane Kisner, Laboratory Manager



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com


Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project Quarterly
Description

Lab Sample No. 1712037-003
Client Sample ID 712DQ
Matrix Drinking Water (Rep)
Date Received 12/05/17 14:45
Date Sampled 12/05/2017 09:00
Date Reported 12/22/2017

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
GC TTHM 524.3									
Total Trihalomethanes	EPA 524.3	0.031	0.001		mg/L	PW	Not Required	12/12/17	
Chloroform	EPA 524.3	0.027	0.001		mg/L	PW	Not Required	12/12/17	
Bromodichloromethane	EPA 524.3	0.004	0.001		mg/L	PW	Not Required	12/12/17	
Dibromochloromethane	EPA 524.3	<0.001	0.001		mg/L	PW	Not Required	12/12/17	
Bromoform	EPA 524.3	<0.001	0.001		mg/L	PW	Not Required	12/12/17	

Approved By 
Diane Kisner, Laboratory Manager



551 State Street
Curwensville, PA 16833

Phone: 1-814-236-3540
Fax: 1-877-267-4152

www.mahaffeylaboratory.com

Certificate of Analysis

Chris Klase
Ridgway Township Municipal Auth.
1537B Montmorenci Rd
Ridgway, Pa 15853

Project Quarterly
Description

Lab Sample No. 1712037-004
Client Sample ID 714DQ
Matrix Drinking Water (Rep)
Date Received 12/05/17 14:45
Date Sampled 12/05/2017 09:15
Date Reported 12/22/2017

Test	Method	Result	RL	MDL	Units	Analyst	Prep Date	Test Date	Qlf.
GC HAA5									
Haloacetic Acids (HAA5)	EPA 552.3	0.024	0.002		mg/L	PW	12/19/17	12/21/17	
Monochloroacetic Acid (MCAA)	EPA 552.3	<0.002	0.002		mg/L	PW	12/19/17	12/20/17	
Monobromoacetic Acid (MBAA)	EPA 552.3	<0.001	0.001		mg/L	PW	12/19/17	12/20/17	
Dichloroacetic Acid (DCAA)	EPA 552.3	0.013	0.001		mg/L	PW	12/19/17	12/20/17	
Trichloroacetic Acid (TCAA)	EPA 552.3	0.011	0.001		mg/L	PW	12/19/17	12/20/17	
Dibromoacetic Acid (DBAA)	EPA 552.3	<0.001	0.001		mg/L	PW	12/19/17	12/20/17	

Approved By

Diane Kisner, Laboratory Manager

Chain of Custody Receiving Document

Receiver: DMZ
Date/Time of check: 12/5/17 1445
Client: Ridgeway Twp
Date Sampled: 12/5/17
Lab #: 1712039

Were The Samples Received On ICE? Yes No

Receiving Temperature: 4

COC/Labels On Bottles Agree? Yes No

If No, Please Explain. _____

Is/Are The Samples Properly Preserved? Yes No

If No, Please Explain. _____

Were Any Of The Samples Out Of Hold? Yes No

If Yes, Please Explain. _____

Were Any Of The Samples Damaged? Yes No

If Yes, Please Explain. _____

Method Of Delivery:

UPS FedEx US Mail Lab Courier Client Other

Does Client Need To Be Contacted, Why? _____

Client Contacted By: _____ Date/Time: _____

Name Of Client Contacted: _____

Discussion/Outcome: _____