



G and C Coal Analysis Lab., Inc.

1341 Hoffman Hollow Road

Summerville, Pa 15864

814-849-2559

Fax: 814-849-8878

ANALYTICAL SERVICES

PO BOX 237

BROCKWAY, PA 15824

Sample Number: B# 47416

Date Reported: 12/19/2016

I. Sample Identification

Location: RIDGWAY TWP WATER AUTH - R.P.M. - LOC ID 802

Source: DISTRIBUTION

Collected By: CLIENT

Date: 12/06/16

Time: 0745

Received By: ELC

Date: 12/07/16

Time: 0700

PWSID: 6240022

Remarks: ASI# 149099

II. Results of Analysis

<u>Analysis</u>	<u>Method</u>	<u>Quantitation Limit</u>	<u>Results</u>	<u>Units</u>	<u>Date/Time Analysis Started</u>	<u>Analyst:</u>	<u>Date/Time Analysis Completed</u>	<u>Analyst:</u>
Total Coliform	COLISURE	NA	NEGATIVE		12/07/16 0840	ELC	12/08/16 1429	ELC
E Coli:	COLISURE	NA	NEGATIVE		12/07/16 0840	ELC	12/08/16 1429	ELC
Residual Chlorine - Free	SM 4500 Cl G	0.02		mg/L				
Residual Chlorine - Total	SM 4500 Cl G	0.02		mg/L				

These results indicate that the above sample **IS NOT** contaminated by Coliform Group Bacteria as defined by the Pennsylvania Safe Drinking Water Act.

Ernie L. Coleman, Microbiology Lab. Supervisor

Analytical Services, Inc.

Billing Address: P.O. Box 237, Brockway, PA 15824
Physical Address: 51 ProChemTech Drive, Brockway, PA 15824
Website: www.asibrookway.com

Laboratory: (814) 265-8749
Fax: (814) 265-8749
Email: analytical@windstream.net


Analytical Report

Customer: Ridgway Twp. Munc. Auth. Laboratory Sample ID: 149488
1537 B Montmorenci Rd. Sample Date and Time: 12/21/16 09:30
Ridgway, PA 15853 Received Date: 12/21/16 9:40
Attention: Carl Gosnell Reported Date: 12/30/16

Sample ID	Site 803 - Casaro Rd - Drinking Water
-----------	---------------------------------------

Microbiological Analysis

Parameter	Result	Units	Quantitation Limit	Method	Date Analyzed	Time	Analyst	Notes
E. Coliform / PA confirmation	Absent	N/A	Cannot Be Present	SM9221E	12/21-23/16	1146; 1124	SC	
Total Coliforms (PA)	Absent	N/A	Cannot be present	SM 9221D	12/21-23/16	1146; 1124	SC	

Reviewed and Approved By: 
For: William Sabatose, Chief Chemical Analyst
PADEP LAB ID#: 33-00411

Date: 01/04/2017
Page 1 of 1