

Analytical Services, Inc.

P.O. Box 237
Brockway, PA 15824-0237

GENERAL CHEMICAL ANALYSIS REPORT

Laboratory (814) 265-8749
FAX (814) 265-8749

CUSTOMER: Ridgway Township Water Authority
164 Ridgway Drive, Suite C
Ridgway, PA 15853
Attn: Carl Gosnell

Page 1 of 1

SAMPLE DATE: 09/08/10
RECEIPT DATE: 09/08/10 at 1:26 pm

REPORT DATE: 09/13/10
ASI ID#: 98218 A thru J

DESCRIPTION OF SAMPLE: PWSID#: 6240022 - See Below

TOTAL ANALYSIS RESULTS:

SAMPLE I.D.	PARAMETER	RESULT	UNIT	QUANTITATION LIMIT	METHOD	BY	DATE & TIME
101 09/08/10 @ 4:45 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.0258	mg/L	0.010	200.8	BB	09/09/10 @ 3:39 pm
102 09/08/10 @ 6:00 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.154	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
103 09/08/10 @ 5:00 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.0226	mg/L	0.010	200.8	BB	09/09/10 @ 3:39 pm
104 09/08/10 @ 8:35 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.114	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
105 09/08/10 @ 5:15 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.163	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
106 09/08/10 @ 6:06 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.182	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
107 09/08/10 @ 8:40 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.0113	mg/L	0.010	200.8	BB	09/09/10 @ 3:39 pm
108 09/08/10 @ 6:00 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.167	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
109 09/08/10 @ 7:15 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.132	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm
110 09/08/10 @ 7:58 am	Lead	<0.005	mg/L	0.005	200.8	BB	09/09/10 @ 3:39 pm
	Copper	0.126	mg/L	0.010	200.8	BB	09/09/10 @ 4:45 pm

We certify that the above reported values were obtained by use of procedures appropriate for the sample as submitted.

BY: William J. Sabatose

DATE: 09/13/10

TITLE: William J. Sabatose, Chief Chemical Analyst