

Analytical Services, Inc.

Billing Address: P.O. Box 237, Brockway, PA 15824
Physical Address: 51 ProChemTech Drive, Brockway, PA 15824
Website: www.asibrookway.com

Laboratory: (814) 265-8749
Fax: (814) 265-8749
Email: analytical@windstream.net


Analytical Report

Customer: Ridgway Twp. Munc. Auth. Laboratory Sample ID: 150784
1537 B Montmorenci Rd. Sample Date and Time: 03/06/17 07:30
Ridgway, PA 15853 Received Date: 03/06/17 8:45
Attention: Carl Gosnell Reported Date: 03/10/17

Sample ID #802 RPM – Drinking Water Sample

Microbiological Analysis

Parameter	Result	Units	Quantitation Limit	Method	Date Analyzed	Time	Analyst	Notes
E. Coli / PA confirmation	Absent	N/A	Cannot be present	SM9221F	3/6-8/17	1623; 1506	SC	
Total Coliforms (PA)	Absent	N/A	Cannot be present	SM 9221D	3/6-8/17	1623; 1506	SC	

Reviewed and Approved By: 
For: William Sabatose, Chief Chemical Analyst
PADEP LAB ID#: 33-00411

Date: 03/13/2017
Page 1 of 1

Analytical Services, Inc.

Billing Address: P.O. Box 237, Brockway, PA 15824
Physical Address: 51 ProChemTech Drive, Brockway, PA 15824
Website: www.asibrookway.com

Laboratory: (814) 265-8749
Fax: (814) 265-8749
Email: analytical@windstream.net


Analytical Report

Customer: **Ridgway Twp. Munc. Auth.** Laboratory Sample ID: **151056**
1537 B Montmorenci Rd. Sample Date and Time: **03/22/17 10:51**
Ridgway, PA 15853 Received Date: **03/22/17 11:26**
Attention: **Carl Gosnell** Reported Date: **03/27/17**

Sample ID	#803 – Casaro – Drinking Water Sample
-----------	---------------------------------------

Microbiological Analysis

Parameter	Result	Units	Quantitation Limit	Method	Date Analyzed	Time	Analyst	Notes
E. Coli / PA confirmation	Absent	N/A	Cannot be present	SM9221F	3/22-24/17	1701; 1548	SC	
Total Coliforms (PA)	Absent	N/A	Cannot be present	SM 9221D	3/22-24/17	1701; 1548	SC	

Reviewed and Approved By: 
For: William Sabatose, Chief Chemical Analyst
PADEP LAB ID#: 33-00411

Date: 03/29/2017
Page 1 of 1