



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpshville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

White Oak Laboratory  
 2997 Ridgway-Johnsonburg Road  
 Ridgeway, PA 15853

Reported: 06/21/2023 14:43

**Lab Sample ID#:** 23F0988-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** 23F0044 - 8A, 8B, 8C  
**Alias Sample ID:** Ridgway Township Municipal Authority 710

**Sample Date:** 06/05/2023 08:15  
**Receipt Date:** 06/08/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Volatile Organics</b>		<b>Analytical Method: EPA524.2 4.1</b>			<b>Prep Method: Purge and Trap</b>		
Chloroform	0.00632	mg/L		0.00100	MJK	06/12/23 13:13	06/12/23 13:13
Bromodichloromethane	0.00230	mg/L		0.00100	MJK	06/12/23 13:13	06/12/23 13:13
Dibromochloromethane	<0.00100	mg/L		0.00100	MJK	06/12/23 13:13	06/12/23 13:13
Bromoform	<0.00100	mg/L		0.00100	MJK	06/12/23 13:13	06/12/23 13:13
Total Trihalomethanes	0.00862	mg/L		0.00100	MJK	06/12/23 13:13	06/12/23 13:13
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	100 %		70-130		MJK	06/12/23 13:13	06/12/23 13:13
<i>Surrogate: 4-Bromofluorobenzene</i>	89 %		70-130		MJK	06/12/23 13:13	06/12/23 13:13

**Lab Sample ID#:** 23F0988-02  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** 23F0044 - 8D  
**Alias Sample ID:** Ridgway Borough Water System 711

**Sample Date:** 06/05/2023 09:00  
**Receipt Date:** 06/08/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Organics</b>		<b>Analytical Method: EPA552.3 1.0</b>			<b>Prep Method: Micro Liquid-Liquid Extra</b>		
Monochloroacetic Acid	<0.00100	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
Monobromoacetic Acid	<0.00100	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
Dichloroacetic Acid	0.00704	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
Trichloroacetic Acid	0.00579	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
Dibromoacetic Acid	<0.00100	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
Total Haloacetic Acids	0.0128	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 17:53
<i>Surrogate: 2-Bromobutanoic acid</i>	95 %		70-130		JH	06/14/23 15:36	06/15/23 17:53



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

White Oak Laboratory  
 2997 Ridgway-Johnsonburg Road  
 Ridgeway, PA 15853

Reported: 06/21/2023 14:43

**Lab Sample ID#:** 23F0988-03  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** 23F0044 - 8E, 8F, 8G  
**Alias Sample ID:** Ridgway Township Municipal Authority 712

**Sample Date:** 06/05/2023 09:55  
**Receipt Date:** 06/08/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time	
<b>Volatile Organics</b>		<b>Analytical Method: EPA524.2 4.1</b>			<b>Prep Method: Purge and Trap</b>			
Chloroform	0.0111	mg/L		0.00100	MJK	06/12/23 13:43	06/12/23 13:43	
Bromodichloromethane	0.00290	mg/L		0.00100	MJK	06/12/23 13:43	06/12/23 13:43	
Dibromochloromethane	<0.00100	mg/L		0.00100	MJK	06/12/23 13:43	06/12/23 13:43	
Bromoform	<0.00100	mg/L		0.00100	MJK	06/12/23 13:43	06/12/23 13:43	
Total Trihalomethanes	0.0140	mg/L		0.00100	MJK	06/12/23 13:43	06/12/23 13:43	
<i>Surrogate: 1,2-Dichlorobenzene-d4</i>	101 %		70-130		MJK	06/12/23 13:43	06/12/23 13:43	
<i>Surrogate: 4-Bromofluorobenzene</i>	89 %		70-130		MJK	06/12/23 13:43	06/12/23 13:43	

**Lab Sample ID#:** 23F0988-04  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** 23F0044 - 8H  
**Alias Sample ID:** Ridgway Borough Water System 714

**Sample Date:** 06/05/2023 09:45  
**Receipt Date:** 06/08/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time	
<b>Organics</b>		<b>Analytical Method: EPA552.3 1.0</b>			<b>Prep Method: Micro Liquid-Liquid Extra</b>			
Monochloroacetic Acid	0.00110	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
Monobromoacetic Acid	<0.00100	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
Dichloroacetic Acid	0.0132	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
Trichloroacetic Acid	0.0116	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
Dibromoacetic Acid	<0.00100	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
Total Haloacetic Acids	0.0259	mg/L		0.00100	JH	06/14/23 15:36	06/15/23 18:19	
<i>Surrogate: 2-Bromobutanoic acid</i>	102 %		70-130		JH	06/14/23 15:36	06/15/23 18:19	